

BEFORE
THE PUBLIC SERVICE COMMISSION OF
SOUTH CAROLINA
DOCKET NO. 93-050-E - ORDER NO. 93-127
FEBRUARY 4, 1993

IN RE: Request of Carolina Power & Light)	ORDER APPROVING
Company for Revision of Area Lighting)	APPLICATION FOR
Service Schedule ALS-77A.)	REVISION OF AREA
)	LIGHTING SERVICE
)	SCHEDULE ALS-77A

This matter is before the Public Service Commission of South Carolina (the Commission) on Carolina Power & Light Company's (CP&L's) request for certain revisions to its Area Lighting Service Schedule ALS-77A. CP&L requests the following four changes:


1. Effective April 1, 1993, add the availability of a 40,000 lumen metal halide light unit.
2. Effective April 1, 1993, discontinue offering installations of the 21,000 and 60,000 lumen mercury vapor flood light units to new area lighting customers. (Existing customers may continue to use and/or obtain additional units of the same type on the same or contiguous property).
3. Effective July 1, 1993, new lights which can be installed on an existing distribution pole without more than one additional span of overhead secondary conductor and without any additional facilities will have a one-year initial contract term instead of the present three-year term.
4. The order of the type of lighting units on the schedule is rearranged to list the most efficient light sources first.

CP&L asserts these proposed changes will promote the use of more efficient lighting sources, will better meet its customers' area lighting needs for safety and security, and will provide customers an additional incentive to utilize existing distribution poles where possible.

After review of the proposed revisions to CP&L's Area Lighting Service Schedule ALS-77A, the Commission finds that the changes should be and are approved. CP&L shall submit ten (10) copies of its revised Area Lighting Service Schedule ALS-77A for the Commission's files.

IT IS SO ORDERED.

BY ORDER OF THE COMMISSION:


Chairman

ATTEST:


Executive Director

(SEAL)